

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2045

Dated: 11/06/2025

Lab Test Report R.No. 153 & Date 04/06/25.

It is certified that an inspection team headed by R.C. YADAV

(Name of Officers with designation) from CHEMIST

(Name of Department/ Office) inspected the St. Jude's Higher Sec. School KHARGONE

(Name & Address of the school) on 03-06-2025 (date of inspection) and found that

the St. Jude's Higher Sec. School KHARGONE (Name of school) has safe drinking water facilities

for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 03 (Three) Months

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

Executive Engineer,
Public Health Engineering Dn
KHARGONE (M.P.)

To

Principal,
St. Jude's Hr. Sec. School
KHARGONE

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


Manager

St. Jude's Hr. Sec. School
Mangrul Road, KHARGONE


Principal

St. Jude's Hr. Sec. School
Mangrul Road, Khargone

**District Water Testing Laboratory,
Public Health Engineering Department.
Diversion Road, Khargone, 451001, Phone-07282-232875
Test Report**

Nature of sample :- Drinking Water Sample / Others		Sample Not collected by District Lab	Unique Identification No.	130/01
TO, Principal St. Jude's Higher Secondary School Mangrul Road, Khargone	Sender's letter no.	SJS25/069	Sender's letter Date	03.06.2025
	DWTL Ref. No	153	DWTL receipt date	03.06.2025
	Date of analysis started	03.06.2025	Date of analysis completed	04.06.2025
	Quantity Of sample	1 liter		


Sample Details


No.	Particulars of Samples
1	St Jude's Higher Secondary School R.O. Sample
2	-
3	-
4	-
5	-

Sample details


No.	Characteristics ,unit and test methods	BIS -10500:2012		RESULTS				
		Desirable Limit	Permissible Limit	1	2	3	4	5
1	Residual Chlorine	0.2	1.0	Nil	-	-	-	-
2	Colour in Hazen scale	5	15	Nil	-	-	-	-
3	Odour	Agreeable	Agreeable	Agreeable	-	-	-	-
4	Iron as Fe in mg/l, IS 3025, Part -53	1.0	1.0	Nil	-	-	-	-
5	Nitrate as NO ₃ in mg/l, PDA Method	45	45	Nil	-	-	-	-
6	Fluoride as F in mg/l IS 3025, Part -60	1.0	1.5	Nil	-	-	-	-
7	Chloride as Cl in mg/l, IS 3025, Part-32	250	1000	26.85	-	-	-	-
8	Total Alkalinity as CaCO ₃ in mg/l, IS 3025, Part -23	200	600	44.44	-	-	-	-
9	Calcium as Ca++ in mg/l, IS 3025, Part -40	75	200	16.8	-	-	-	-
10	Magnesium as Mg++ in mg/l, IS 3025, Part -46	30	100	8.7	-	-	-	-
11	Sulphate as SO ₄ in mg/l, BIS 3025 (Part -24)	200	400	5.0	-	-	-	-
12	pH APHA 22 nd IS 3025, Part -11	6.5 to 8.5	6.5 to 8.5	6.98	-	-	-	-
13	Turbidity in NTU, IS 3025, Part-10	1.0	5.0	0.5	-	-	-	-
14	Total hardness as CaCO ₃ in mg/l, IS 3025, Part-21	200	600	58.58	-	-	-	-
15	Conductivity at 25°C in micromhos/cm, IS 3025, Part-14	-	-	144	-	-	-	-
16	TDS By meter IS 3025, Part-16	500	2000	65	-	-	-	-
17	Phenolphthalein Alkalinity as CaCO ₃ in mg/l IS 3025, Part	-	-	Nil	-	-	-	-
18	Faecal Coliform (TTC) per 100 ml IS APHA23rd edition, 9211 B	NIL		-	-	-	-	-
19	Total coliform per 100 ml IS APHA23rd edition 9211 B	NIL for treated water and water in distribution system		Nil	-	-	-	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 10 days from the date of issue of report. (For tests from S No. 1 to——)


Assistant Chemist


Chemist
DISTRICT LABORATORY
P. H. E. DEPARTMENT KHARGONE


Manager
Private Test Reports
St. Jude's Hr. Sec. School
Mangrul Road, KHARGONE


Principal
St. Jude's Hr. Sec. School
Mangrul Road, Khargone